



## Addendum #1 – Brooklyn Bridge Park Request for Proposals for Acoustic Renovation Services

**September 15, 2023**

This document serves as a response to questions for the Request for Proposals for Public Restroom Acoustic Renovation Services, issued by Brooklyn Bridge Park Corporation d/b/a Brooklyn Bridge Park (“BBP”) on September 5, 2023. Please read carefully the RFP (including this Addendum) before preparing and submitting a proposal.

Item #	RFI	Response
1.	Is an acoustical engineer involved? Please advise if drawings with layout will be provided.	Yes. BBP will determine if drawings with layouts will be necessary during the course of construction.
2.	Please advise which walls are to be demolished/removed and new walls installed.	The affected walls include the following: western wall in the Men’s restroom, southern wall in men’s restroom, ceiling in men’s restroom, the southern wall in the women’s restroom, and the ceiling in the women’s restroom.
3.	Please confirm who is responsible for all electrical disconnections/lighting removal/replacement.	All electrical and light fixture work is to be completed by the awarded contractor or their respective subcontractor.
4.	Are all plumbing fixtures to remain?	All plumbing fixtures removed shall be salvaged and reinstalled. No new plumbing fixtures are included in the scope of work.
5.	Please confirm who is responsible for all HVAC disconnections, grille replacement and connections	All HVAC work is to be completed by the awarded contractor or their respective subcontractor.

6.	Please confirm if tiles are to be replaced and if so, provide spec and or desired tile type.	The wall tiles specs will be provided after awarding the contract. Please assume 3"x6" subway tile for proposal cost estimating.
7.	Please confirm if existing stainless steel sink vanities in both bathrooms are to remain.	Confirmed, existing sinks are to remain in place.